

Certelec Ltd

Electrical Equipment Inspection & Test Record Form Vb (Abbreviated Copy)

Certificate Number: 218248

Client: Chip Jenkins Jazz

Certificate Valid until 20/12/2007

Description	Serial Number	a) Environment/ Use b) Disconnect	Visual Inspection (4 cats) P/F	Continuity	Insulation	Functional Check	Operational	Leak.	Overall Result Passed or fail OK to use	Date Tested
Active Speaker	Z60520123AC	a) P b) P	P	0.092	n/a	P	0.041 P	0.22 P	P	19/12/2006
Active Speaker	Z60690262AC	a) P b) P	P	0.747	n/a	P	0.042 P	0.21 P	P	19/12/2006

For further details of test results please apply to Chip Jenkins or Certelec Ltd as below.

Certelec Ltd confirm that the equipment shown above has passed a full inspection and testing to the IEE Code of Practice For In-Service Inspection and Testing of Electrical Equipment and that this is a summary copy of the Certificate issued to Chip Jenkins Jazz.

Inspection & Testing carried out by: Certelec Ltd, The Mews, 5c Watts Lane, Eastbourne, BN21 1NP
Electrical Inspection & Testing Company, Tel: 01323 735892 , email: enquiries@certelec.com



This copy certificate was developed by Certelec Ltd and is based on a model shown in Appendix V of the IEE Code of Practice For In-Service Inspection and Testing of Electrical Equipment.